



Instrument Calibration Sheet

Gen2 Pharmaceuticals

Ireland

Page 1 of 1

Date Printed

15/10/14 12:50:53

Tag	TT-RE005-101	Description	Temperature Transmitter on 101
SOP	AN1220 SOP 2	Location	Reactor Floor
Safety	Working At Height	Service	N/A
Work Order	P/14/42/0006	Serial No	4563566
Manufacturer	E+H	Plant	NitrogenDistribution
Tolerance Typ	Units	Interval	1 Days
Certificate No	N/A	Tol Unit In	-2.0 To 2.0
Tolerance%	-1.0 To 1.0	Tol Unit Out	-2.0 To 2.0
		Model	N/A
		Class	Critical
		Next Due Date:	10/2014
		Input Range	0.0 To 200.0 °C
		Output Range	0.0 To 200.0 °C

Ref Type/s Used

Stand Equip	Reference#1	Reference#2	Reference#3	Reference#4
Tag	TT-REF-001	N/A	N/A	N/A
Description	Temperature Reference	N/A	N/A	N/A
Function	0 to 500 Deg C	N/A	N/A	N/A
Accuracy	+/- 0.25 %	N/A	N/A	N/A
Serial No	T3544355	N/A	N/A	N/A
Certificate No	CE3453535	N/A	N/A	N/A
Traceability	UKAS	N/A	N/A	N/A
Due Date	19/12/14	N/A	N/A	N/A

Calibration Values (Before : Passed)

Cal. Points	Input	Reading	Error	-Output MPE	Output MPE
0.0	0.0	0.1	0.1	-2.0	2.0
100.0	100.0	99.6	-0.4	-2.0	2.0
200.0	200.0	201.3	1.3	-2.0	2.0

Labels Updated Yes No

Failed By User No Yes

Tasks General Condition

Setup Comments

N/A

Entry Comments

Calibration carried out successfully.

Acceptance Comments

Work Order completed and verified.

Conducted By Felix Stubner

Date 15/10/14

Accepted By Eren Jaeger

Date 15/10/14